



**Building Permission Cell, Greater Mumbai / MHADA**

(A designated Planning Authority for MHADA layouts constituted as per government regulation No. TPB4315/167/CR-51/2015/UD-11 dt.23 May, 2018.)

**INTIMATION OF APPROVAL (IOA) for Zero FSI**



No.MH/EE/BP Cell/GM /MHADA -106/ **1336** /2023  
Date : **18 SEP 2023**

ITC Cell,  
M. H. & A. D. Authority  
Inward No.: 2586  
Date: 25.09.2023

का. अ. / इफक (ह. अ.)
पश्चिम
जावक क्र.
ET-2001 25 SEP 2023

To,  
M/s Lotus logistic Builders & Developers.  
C.A to owner Azad Nagar Sai Chhaya CHS  
And Azad Nagar Himalaya CHS  
1301, Lotus Trade centre, Sahakar Nagar  
NewLink Road, Andheri (W) Mumbai -53

**Sub:** Proposed redevelopment of existing building no. 49 known as Azad Nagar Sai Chhaya CHS Ltd. and building no. 50 known as Azad Nagar Himalaya CHS Ltd. on plot bearing C.T.S. No. 183(pt) of Village - Ambivali, Azad Nagar MHADA Layout at Azad Nagar Road no. 3, Off Veera Desai Road, Andheri (West), Mumbai – 400058.

**Ref.:** Application Letter for Zero FSI I.O.A. From . L.S. Shri. Jitendra G. Dewoolkar of M/s. Ellora Project Consultant Pvt. Ltd.dtd. 23.08.2023

Dear Applicant,

With Reference to your Notice U/S 45 (1) (ii) of MRTP Act 1966 submitted with letter dtd.10.04.2023, along with the plans, Sections Specifications and Description and further particulars and details of your **Proposed redevelopment of existing building no. 49 known as Azad Nagar Sai Chhaya CHS Ltd. and building no. 50 known as Azad Nagar Himalaya CHS Ltd. on plot bearing C.T.S. No. 183(pt) of Village - Ambivali, Azad Nagar MHADA Layout at Azad Nagar Road no. 3, Off Veera Desai Road, Andheri (West), Mumbai – 400058.** furnished to this office under your letter, dated 23.08.2023, I have to inform you that I may approve the building or work proposed



to be erected or executed, and I therefore hereby formally intimate to you U/S 45 (1) (ii) of MRTP Act 1966 as amended upto date, my approval by reasons thereof subject to fulfillment of conditions mentioned as under:-

**A: CONDITIONS TO BE COMPILED WITH BEFORE STARTING THE WORK.**

1. That the commencement certificate U/s-44/69(1) of MRTP Act shall be obtained.
2. That structural Engineer shall be appointed and supervision memo of as per appendix-IX of D.C. Regulation – 5(3) (9) shall be submitted by him.
3. The structural Design and calculations for the proposed work accounting for system analysis as relevant IS code along with Plan shall be submitted before C.C.
4. Janata Insurance Policy shall be submitted.
5. Requisitions of clause as per DCPR 2034 shall be complied with and records of quality of work, verification report, etc. shall be maintained on site till completion of the entire work.
6. Bore well shall be constructed in consultation with H.E./MCGM if required.
7. That the work shall be carried out between 10 a.m. to 6 p.m. as per circular u/no. CHE/DP/7749/GEN dt.07.06.2016.
8. Information Board shall be displayed showing details of proposed work, name of Owner, Developer, Architect, R.C.C. Consultant etc.
9. Necessary deposit for erection/display of hording or the flex of size m to m for the advertisement of proposal shall be made.
10. That the qualified/registered site supervisor through Architect /structural Engineer shall be appointed.
11. NOC Listed below shall be submitted
  - a. Superintendent of Garden (SG)/ Tree NOC for tree Cutting/Transplanting.
  - b. SWD department
  - c. PCO
  - d. H.E.
  - e. S.P
  - f. A.E.W.W.
  - g. A.A & C
  - h. S.W.M.
  - i. M & E
  - j. Water trunk main /aqueduct Remarks. A.A.W.W
  - k. Maha Nagar Gas

12. That the specific NOC as per Hon'ble Supreme Court of India (SLP Civil no. D-23708/2017) order in dumping ground court case dt. 15.03.2018 shall be submitted from concerned department/SWM department along with Bank Guarantee.
13. That the registered undertaking and indemnity bond for Zero FSI shall be submitted.


--Sd--

( Rupesh M. Totewar)  
**Executive Engineer B.P. Cell(W.S)**  
**Greater Mumbai/ MHADA**

**Copy submitted for information please.**

**Copy with plan to:**

- 1) Chief Officer/Mumbai Board.
- 2) Asst. Commissioner 'K/W' Ward(MCGM)
- 3) Dy.Che.B.P//G.M/MHADA (P.A)
- ✓ 4) Chief ICT officers/MHADA for information &upload on MHADA Website
- 5)Executive .Eng./ Bandra Division/ Mumbai Board
- 6) A.A. & C. 'K/W' Ward (MCGM)
- 7) A.E.W.W. 'K/W' Ward (MCGM)
- 8) L.S. Shri Jitendra G. Dewoolkar of M/s. Ellora Project Consultant Pvt. Ltd

  
( Rupesh M. Totewar)  
**Executive Engineer B.P. Cell(W.S)**  
**Greater Mumbai/ MHADA**

## SPECIAL INSTRUCTIONS

1. THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.
2. "Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be
  - a. Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street.
  - b. Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.)-of such building.
  - c. Not less than 92 ft.( Town Hall) above Town Hall Datum.
3. Your attention is invited to the provision of Section 152 of the Act where by the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.
4. Your attention is further drawn to the provision about the necessity of submitting occupation certificate with a view to enable the V.P.& C.E.O./ MHADA to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance if necessary.
5. Proposed date of commencement of work should be communicated.
6. One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

Attention is drawn to the notes accompanying this Intimation of Approval.

## NOTES

1. The work should not be started unless objections are complied with.
2. A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
3. Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.
4. Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
5. Water connection for constructional purpose from MHADA mains shall not be taken without approval from concerned Executive Engineer of Mumbai Board.
6. The owners shall intimate the Hydraulic Engineer or his representative in Wards at least 10 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilized for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presumed that Municipal tap water has been consumed on the construction works. and bills preferred against them accordingly.
7. The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or Public Street by the owner/ architect /their contractors, etc without obtaining prior permission from the Ward Officer of the area.
8. The work above plinth should not be started before the same is shown to this office Junior Engineer/Sectional Engineer/Assistant Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimensions.
9. The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.
10. All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.
11. The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
12. No work should be started unless the existing structures proposed to be demolished are demolished.
13. The Intimation of Approval is given exclusively for the purpose of enabling you to proceeds further with the arrangements of obtaining No Objection Certificate from the Competent Authorities and in the event of your proceeding with the work

either without an intimation about commencing the work or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Approval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act 1966, (12 of the Town Planning Act), will be withdrawn.

14. The bottom of the over head storage work above the finished level of the terrace shall not be less than 1.20 Mt. and not more than 1.80 mt.
15. It is to be understood that the foundations must be excavated down to hard soil.
16. The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
17. The water arrangement to be carried out in strict accordance with the Municipal requirements.
18. No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Hon. VP/CEO /MHADA.
19. All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbet pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfections each not exceeding 1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible by providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.
20. No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
21. Louvres should be provided as required by Bye law No. 5 (b)/b. Lintels or Arches should be provided over Door and Windows opening/ c. The drains should be laid as require under Section 234-1(a)/d. The inspection chamber should be plastered inside and outside.
22. All Precautionary safety measures shall be done on construction site while executing the work with prior consulation of appointed structural Engineer & Geo Technical Engineer. Special precaution shall be taken during Excavation & thereafter.

( Rupesh M. Totewar)

**Executive Engineer B.P. Cell(W.S)  
Greater Mumbai/ MHADA**

