



Building Permission Cell, Greater Mumbai / MHADA

(A designated Planning Authority for MHADA layouts constituted as per government regulation no. TPB4315/167/CR-51/2015/UD-11 dt.23 May, 2018.)

INTIMATION OF APPROVAL (IOA)

No. MH/EE/BP Cell/GM/ MHADA-25/1327/2023

Date: 07 AUG 2023

To,
Executive Engineer
Kurla Division/ Mumbai Board
Griha Nirman Bhavan
Kala Nagar, Bandra (E),
Mumbai 400051.

REC Cell,
M. H. & A. D. Authority
Inward No.: 2031
Date: 09.08.2023

Subject :- Proposed construction of building on property bearing. CTS no. 6 (Pt), open plot O.B. No. 9 (Old O.B. No. 8/1, 8/2, 8/3) Near Sulabha School, Tilak Nagar, Village Chembur, , Mumbai. For MH& A D Board.

Owner :- MHADA

Turnkey project allotted to M/s. HalkoInfraprojects

Reference :- Your letter vide No. EE/Kurla/MB/26.05/2023 dtd. 15.06.2023

Sir,

This is to inform you that the plans for the above mentioned work submitted by you are hereby approved subject to the compliance of following conditions:

A: CONDITIONS TO BE COMPILED WITH BEFORE STARTING THE WORK.

1. That the compound wall shall be constructed.
2. That the all requisite payment fees, deposits, premium shall be paid.
3. That the low-lying plot shall be filled up to reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc. and shall be levelled, rolled, consolidated and sloped towards road side before starting the work.
4. That the adequate & decent temporary sanitary accommodation shall be provided for construction workers.
5. That structural Engineer shall be appointed and supervision memo of as per appendix-IX of D.C. Regulation – 5(3) (9) shall be submitted by him.

6. That the structural Design and calculations for the proposed work accounting for system analysis as relevant IS code along with plan shall be submitted before 30 days.
7. That the Janata Insurance Policy shall be submitted within 30 days.
8. That the requisitions of clause 45 & 46 of DCR 91 shall be complied with and records of quality of work, verification report, etc. shall be maintained on site till completion of the entire work.
9. That the specific NOC as per Hon'ble supreme court of India (S.L.P. Civil No. D23708/2017) order in dumping ground court case dtd. 15.03.2018 shall be obtained from concerned department / S.W.M. Department shall be submitted within 30 days.
10. That the Bore well shall be constructed in consultation with H.E./MCGM.
11. That the work shall be carried out between 6.00 a.m. to 10.00 p.m. as per circular u/no. CHE/DP/7749/GEN dt.07.06.2016.
12. That the information Board shall be displayed showing details of proposed work, name of owner, developer, architect / LS, R.C.C. consultant etc.
13. The safety measure shall be taken on site as per relevant provision of I.S. code and safety regulation
14. That the extra water and sewerage charges shall be paid to Assistant Engineer, Water Works 'M' West Ward up to date.
15. That the up-to-date paid receipts of A. A. & C. M(West) ward shall be submitted.
16. That the regular/ sanctioned/ proposed road lines shall be got demarcated at site through the concerned authorities before starting the work.
17. The payment of advance for providing treatment at construction site to prevent epidemics like Dengue, Malaria etc. shall be made to the Insecticide Officer of the concerned ward office and provision shall be made as and when required by Insecticide Officer for inspection of water tanks by providing safe and stable ladder, etc. and requirements as communicated by the Insecticide Officer shall be complied with.
18. That remarks from SP (P&D) for drainage connection shall be submitted.
19. That the authorized private pest control agency to give anti-larval treatment on construction site shall be appointed and conditions of circular u/No.AMC/WS/H/9346/29.3.2010 shall be complied with.
20. That the N.O.C. from local electric supply co. shall be submitted.
21. That the NOC from S.G./Consultant remarks shall be submitted.
22. That the qualified registered site supervisor through architect/structural engineer shall be appointed & his name and license No. duly revalidated shall be submitted.
23. That the soil investigation report from Geologist shall be submitted within 30 days.

24. That adequate care in planning, designing and carrying out construction shall be taken in the proposed building to provide for the consequence of settlement of floors and plinth filling etc.
25. That the applicable taxes including labour welfare cess, to state/central government and local authority shall be paid.
26. That the remarks regarding rain water harvesting shall be submitted and provision shall be made in construction of the project accordingly
27. That the final outcome of parking provision by Govt. of Maharashtra, UDD-1 shall be binding on you.
28. That the plinth shall be got checked by your office.
29. That the Remarks of concerned authorities / empaneled consultants for the approved plan, if differing from the plans submitted for remarks, shall be submitted for : a) S.W.D., b) Roads, c) Sewerage, d) Water Works, e) Tree authority, f) Hydraulic Engineer, g) PCO, h) NOC from Electric Supply Company.
30. That the Material testing report for construction materials used at site shall be taken as per required frequency regularly checked by your office.
31. That the yearly progress report of the work will be submitted by the Architect.
32. That the Civil Aviation NOC from A.A.I. shall be submitted.
33. That the design and specification for mechanized parking system shall be obtain from the Consultant/Manufacturer shall be submitted.
34. Architect, Structural consultant shall verify the scheme is progress as per sub-structure, super structure & OHT.
35. That all referred work shall be checked by your office.
36. That the C.C shall be obtained after compliance of above conditions and after completion of Plinth.

B:GENERAL CONDITIONS TO BE COMPILED BEFORE O.C

1. That the dust bin will be provided.
2. That 3.00 mt. wide paved pathway upto staircase will be provided.
3. That the open spaces as per approval, parking spaces and terrace will be kept open.
4. That the name plate/board showing Plot No., Name of the Bldg. etc. will be displayed at a prominent place.
5. That carriage entrance shall be provided as per design of registered structural engineer and carriage entrance fee shall be paid.
6. That terraces, sanitary blocks, nahanis in kitchen shall be made Water proof and same shall be provided by method of pounding and all sanitary connections shall be leak proof and smoke test shall be done in presence of licensed plumber.

7. That final N.O.C. from concerned authorities / empanelled consultants for :- a) S.W.D., b) Water Works, c) CFO /Fire Fighting Provisions, d) Tree authority, e) Hydraulic Engineer, f) MHADA / MCGM if any, g) Assessment shall be submitted before occupation.
8. That Structural Engineer's final Stability Certificate along with up to date License copy and R.C.C. design canvas plan shall be submitted.
9. That final completion plans for Completion of work on site shall be submitted.
10. That one set of plans mounted on canvas shall be submitted
11. That the building completion certificate in prescribed format as certified by architect/ licensed surveyor shall be submitted
12. That the certificate to the effect that the licensed surveyor has effectively supervised the work and has carried out tests for checking leakages through sanitary blocks, termites, fixtures, joints in drainage pipes etc. and that the workmanship is found very satisfactory shall be submitted.
13. That the structural stability certificate from registered structural engineer on the project shall be submitted.
14. That the completion certificate from the licensed site supervisor appointed by MHADA on the project shall be submitted
15. That Site Supervisor certificate for quality of work and completion of the work shall be submitted in prescribed format.
16. That the topmost elevation level of the building certified by Airport Authority of India mentioning that the height of the building is within the permissible limits of Civil Aviation N.O.C. shall be submitted before O.C.C.
17. That the final NOC from S.G. shall be submitted.
18. That DCC from licensed plumber shall be submitted with acceptance of AE (BP) Spl. Cell.
19. That No dues pending certificate from Asst. Engineer (W.W.) "M" ward shall be submitted.
20. That the certificate from A.A. & C (M. Ward) regarding upto date payments of the property taxes shall be submitted.
21. That the completion certificate from Ex. Engineer (S.P.) for drainage lines and connections shall be submitted.
22. That the completion certificate from Executive Engineer (S.W.D.) shall be obtained.
23. That the debris shall be removed before submitting the building completion certificate and requisite deposit shall be paid before starting the work towards faithful compliance thereof.

24. That the completion certificate for provision of rain water harvesting as per design prepared by consultant in the field shall be submitted.
25. That some of the drains shall be laid internally with C.I. pipes.
26. That the dust bin shall be provided as per E.E's circular No. CE/9296/11 of 26.06.1978.
27. That 10 ft. wide Paved pathway upto staircase shall be provided.
28. That the surrounding open spaces, Parking spaces and terrace shall be kept open and un-built upon and shall be levelled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
29. That the provision of Rain water harvesting as per design prepared by approved consultant in the field shall be made to the satisfaction of concerned authority
30. That the Vermiculture bins for disposal of wet waste as per the design and specification of Organization/Individuals specialized in this field, as per the list furnished by solid waste management dept. of MCGM shall be provided to the satisfaction of Municipal Commissioner.
31. That the certificate from Lift Inspector regarding satisfactory installation and operation of lift will be submitted.
32. That the Recreational ground (if any) shall be kept open to all public of the layout with the separate gate for access and accordingly, display board shall be fixed.
33. That the dry and wet garbage shall be separated and the wet garbage generated in the building shall be treated separately on the same plot by the residents/ occupants of the building in the jurisdiction of MCGM. The necessary condition in sale agreement to that effect shall be incorporated by Mumbai Board .
34. That the certificate under 270-A of the B.M.C. Act shall be obtained from H.E.'s department regarding adequacy of water supply.

Yours Faithfully,

--Sd--

(Anil N. Rathod)

**Executive Eng./B.P. Cell (E.S.)
Greater Mumbai/MHADA**

Copy Submittedto:-

- 1) The Hon'ble Chief Officer / M.B., for information and necessary action please.
The above approval parameter may please be incorporated in layout while getting approval of the layout of Tilak Nagar MHADA Colony, Chembur. It is also requested that, the difference if any, observed in land area and BUA allotted the

same may please be informed to this department of B.P./MHADA within a period of one week.

A set of approved plan for information and necessary action please.

- 2) The Architect/ Layout Cell/ M.B., for information and necessary action please.

The above approval parameter may please be incorporated in layout while getting approval of the layout of Tilak Nagar MHADA Colony, Chembur. It is also requested that, the difference if any, observed in land area and BUA allotted the same may please be informed to this department of B.P./MHADA within a period of one week.

A set of approved plan for information and necessary action please.

- 3) Executive Engineer (Kurla Division), for information and necessary action please.

The set of plans attached herewith for your information & necessary action. The plans are approved as per proposal submitted by Mumbai Board vide no. EE/KD/MB/84/2023 dtd. 05.01.2023

The above approval parameter may please be incorporated in layout while getting approval of the layout of Tilak Nagar MHADA Colony, Chembur

It is also requested that, the difference if any, observed in land area and BUA allotted the same may please be informed to this department of B.P./MHADA within a period of one week.

A set of approved plan for information and necessary action please.

4. Deputy Chief Engineer/ BP Cell/ MHADA.

- ✓ 5. Chief ICT Officer/MHADA for information & Uploaded on MHADA website.

6. Asst. Commissioner 'M' West Ward (MCGM)

7. A.A. & C. 'M' West Ward (MCGM)

8. A.E.W.W. 'M' West Ward (MCGM)

9. Architect Chandrakant Gorule of M/s. Vision Arch. for information and necessary action. It is directed to comply the remarks and conditions of LOA before starting the work and to carryout the work as per approved plans.

10. Site Supervisor, Shri. Manish Mehta, for information and necessary action.

It is directed to obtain the soil testing before start of work and to execute the work as per sanctioned plan and regularly supervise the work and maintain the quality of material by testing the material periodically and maintain the reports of the work.


(Anil N. Rathod)

**Executive Eng./B.P. Cell (E.S.)
Greater Mumbai/MHADA**

SPECIAL INSTRUCTIONS

1. THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.
2. "Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be
 - a. Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street.
 - b. Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.)-of such building.
 - c. Not less than 92 ft.(Town Hall) above Town Hall Datum.
3. Your attention is invited to the provision of Section 152 of the Act where by the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.
4. Your attention is further drawn to the provision about the necessity of submitting occupation certificate with a view to enable the V.P. & C.E.O./ MHADA to inspect your premises and to grant a permission before occupation and to levy penalty for non-compliance if necessary.
5. Proposed date of commencement of work should be communicated.
6. One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

Attention is drawn to the notes accompanying this Intimation of Approval.

NOTES

1. The work should not be started unless objections are complied with.
2. A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
3. Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.
4. Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
5. Water connection for constructional purpose from MHADA mains shall not be taken without approval from concerned Executive Engineer of Mumbai Board.
6. The owners shall intimate the Hydraulic Engineer or his representative in Wards at least 10 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilized for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presumed that Municipal tap water has been consumed on the construction works. and bills preferred against them accordingly.
7. The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or Public Street by the owner/ architect /their contractors, etc. without obtaining prior permission from the Ward Officer of the area.
8. The work above plinth should not be started before the same is shown to this office Sectional Engineer/Assistant Engineer/Deputy Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimensions.
9. The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.
10. All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.
11. The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
12. No work should be started unless the existing structures proposed to be demolished are demolished.

13. The Intimation of Approval is given exclusively for the purpose of enabling you to proceed further with the arrangements of obtaining No Objection Certificate from the Competent Authorities and in the event of your proceeding with the work either without an intimation about commencing the work or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Approval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act 1966, (12 of the Town Planning Act), will be withdrawn.
14. The bottom of the overhead storage work above the finished level of the terrace shall not be less than 1.20 Mt. and not more than 1.80 mt.
15. It is to be understood that the foundations must be excavated down to hard soil.
16. The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
17. The water arrangement to be carried out in strict accordance with the Municipal requirements.
18. No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Hon'ble VP/CEO-MHADA.
19. All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbet pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfections each not exceeding 1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible by providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.
20. No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.
21. Louvers should be provided as required by Bye law No. 5 (b)/b. Lintels or Arches should be provided over Door and Windows opening/ c. The drains should be laid as require under Section 234-1(a)/d. The inspection chamber should be plastered inside and outside.


(Anil N. Rathod)

**Executive Eng./B.P. Cell (E.S.)
Greater Mumbai/MHADA**